



**Crabtree, Rohrbaugh & Associates - Architects**  
 401 East Winding Hill Road  
 Mechanicsburg, PA 17055  
 Maryland • Pennsylvania • Virginia • West Virginia

**Contractor:** McCarty and Sons  
**Address:** 1161 Steinmetz Road  
**Address:** 0  
**City, State, ZIP:** Ephrata, PA 17522

**Project :** Northern Lebanon Fieldhouse  
**Address:** & Athletic Improvments

**Change Order No:** 7  
**Date:** 8/22/2022  
**Architect's Project No:** 3447

**The contract is changed as follows:**

**Contract Type:** Electrical  
**Notice to Proceed Date:** 12/28/2021

Add \$	1,285.25
Deduct	

To provide conduit repair at turf field bleachers. This conduit was not properly marked by ECI and was damaged by Lobar.  
 See the attached McCarty COR EC-09 (#8395) dated August 17, 2022.

Additional Documentation Attached

***This Change Order is not valid until signed by the Owner, Architect, and Contractor.***

Original Contract Amount	\$	1,188,234.00
Net Change by previous Change Orders	\$	(17,536.34)
Contract Amount prior to this Change Order	\$	1,170,697.66
Net Change by this Change Order	\$	1,285.25
Contract Amount after this Change Order	\$	1,171,982.91

Contract Time adjustment as a result of this Change Order \_\_\_\_\_ Days  
 Date of Substantial Completion as of this Change Order \_\_\_\_\_

**Architect**  
 Crabtree Rohrbaugh & Assoc.  
 401 East Winding Hill Road  
 Third Floor  
 Mechanicsburg, PA 17055

**Contractor**  
 McCarty and Sons  
 1161 Steinmetz Road  
 0  
 Ephrata, PA 17522

**Owner**  
 Northern Lebanon SD  
 345 School Drive  
 0  
 Fredericksburg PA 17026

By: \_\_\_\_\_

By: \_\_\_\_\_

By: \_\_\_\_\_

Date: \_\_\_\_\_

Date: \_\_\_\_\_


Date: \_\_\_\_\_

# PROPOSAL



## McCARTY & SON INC.

*"Quality and Pride in Workmanship"*



**ELECTRICAL CONTRACTORS**  
Commercial & Industrial

1161 Steinmetz Road  
Ephrata, PA 17522

(717) 626-9580  
(717) 721-7680  
Email: [bmccarty@dejazzd.com](mailto:bmccarty@dejazzd.com)

No. 8395

PROPOSAL SUBMITTED TO <b>Northern Lebanon School District</b>	PHONE	DATE <b>August 17, 2022</b>
STREET <b>345 School Drive</b>	PROJECT NAME <b>Conduit Repair</b>	
CITY, STATE and ZIP CODE <b>Fredericksburg, PA 17026</b>	PROJECT LOCATION <b>Northern Lebanon Athletic Field Project</b>	
ARCHITECT	ATTENTION <b>Attn: Bradly Reist</b>	

We hereby submit specifications and estimates for:

Time and material work that has been completed to fix (2) 2" conduits that were broken by excavator in front of soccer field bleacher, pull conductors back and splice.

Per discussion with Collin on 8-17-22, this COR is acceptable and formal change order will be prepared for formal approval. The amount will be deducted from ECI contract and Colling will notify them directly.  
**BK 8-18-22**

Price Quotation: **1,285.25**

Thank you for giving us the opportunity to supply you with a quote for this work.

**We Propose** hereby to furnish material and labor – complete in accordance with above specifications, for the sum of:

**One Thousand, Two Hundred, Eighty-Five and 25/100** dollars (\$ **1,285.25** ).

Payment to be made as follows:

All material is guaranteed to be as specified. All work to be completed in a workmanlike manner according to standard practices. Any alteration or deviation from above specifications involving extra costs will be executed only upon written orders, and will become an extra charge over and above the estimate. All agreements contingent upon strikes, accidents or delays beyond our control. Owner to carry fire, tornado and other necessary insurance. Our workers are fully covered by Workman's Compensation Insurance.

**Acceptance of Proposal** – The above prices, specifications and conditions are satisfactory and are hereby accepted. You are authorized to do the work as specified. Payment will be made as outlined above.

Date of Acceptance: \_\_\_\_\_

Authorized Signature 

Note: This proposal may be withdrawn by us if not accepted within **15** days.

Signature \_\_\_\_\_



Electrical Contractors

Commercial & Industrial

1161 Steinmetz Road  
Ephrata, PA 17522

(717) 626-9580

(717) 721-7680

bmccarty@dejazzd.com

August 17, 2022

Northern Lebanon School District  
345 School Drive  
Fredericksburg, PA 17026

RE: Northern Lebanon Athletic Field Project  
Proposal 8395 Breakdown

To Whom It May Concern;

Below is a price for time and material work that has been completed to fix (2) 2" conduits that were broken by excavator in front of soccer field bleacher, pull conductors back and splice:

Material:

- New Construction
- Renovations
- Fire Alarm System Installation
- Security System Installation
- Sound System Installation
- Data Networking
- Fiber Optics
- Power Distribution
- Control Wiring
- Phone and Cable Wiring
- Outdoor Lighting
- Distribution 13KV
- Bucket Truck Service
- Design - Build
- Plant Maintenance

- 20' 2" PVC Conduit
- 2 2" PVC Coupling
- 400' String
- 7 2 Conductor #4 Polaris Lug
- 3 Red Wire Nuts

Material:	267.29
Overhead & Profit:	40.10
Labor (11.5 hrs.):	945.53
Bid Bond:	32.33

Price quotation: 1,285.25

If you have any questions, please feel free to give our office a call.

Sincerely,

Kyle H. McCarty